



LEGENDA

- ETAPA LT OLINDINA-PORTO SERGIPE C1 - 500kV - LEILÃO N° 002/2018 - LOTE 07/
- EIXOS DE REFERENCIA DA SUBESTAÇÃO
- TUBO DRENO Ø0,20m, DECLIVIDADE 0,5%
- TUBO CONCRETO DIÂMETRO INDICADO, DECLIVIDADE 0,5%
- BOCA DE LOBO
- CAIXA DE PASSAGEM
- SAÍDA DOS RAMAIS (VAZÃO MÁX. ESTIMADA 470 L/s)

NOTAS

- 1- DIMENSÕES EM MILÍMETRO. / DIMENSIONS IN MILLIMETER.
- 2- A PARTIR DA SAÍDA, CONDUZIR A TUBULAÇÃO NO SENTIDO DO PONTO MAIS BAIXO DO TERRENO, E DEVERÁ SER ENCAMINHADA EM CURVA DE NÍVEL PARA EVITAR EROSÕES. TODAS AS SAÍDAS POSSUIRÃO DISSIPADORES DE ENERGIA (ANTES DO DEFLÚVIO).
- 3- A REDE DE DRENAGEM, COM VAZÃO MÁXIMA ESTIMADA 470 L/s, NÃO SERÁ INTERLIGADA À REDE EXISTENTE.

DESENHOS DE REFERÊNCIA:

SF01818-SE-PS-C-DE-1001 - SE PORTO SERGIPE 500kV - ARRANJO DOS EQUIPAMENTOS - PLANTA

0A	13/06/19	OT	OT	EBFB	EBFB	EBFB
Rev	Rev. Date	Created By	Verif. By	Approved By		

Sterlite São Francisco Energia S.A.	ΟΥΡΟΥΝΟΥ ΑΓΙΟΥ ΠΑΥΛΟΥ ΣΩΣΤΙΑΝΟΠΟΛΙΣ ΕΒΡΟΥ ΣΥΛΛΕΞΙΜΟΤΗΤΑ ΕΡΓΩΝ ΣΥΛΛΕΞΙΜΟΤΗΤΑ ΕΡΓΩΝ	
	SE PORTO SERGIPE 500kV DRENAGEM - PLANTA	

Approved By: _____ Date of Approv.: _____	
PWA SF01818-SE-PS-C-DE-1001	Date: 08/10/18 Scale: 1:750 Sheet: 1/1
Created By: EBFB Verif. By: EBFB Approved By: EBFB	Drawing Number: SF01818-SE-PS-C-DE-1001